

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. :- 137

Dated: - 07/05/2025

It is certified that an inspection team headed by Hareet Kaur Bachchu

(Name of Officers with designation) from Assistant Engineer, P.H. Sub. Division Bihar Sharif

(Name of Department/ Office) inspected the EDUEN WORLD SCHOOL SALEMPUR SOHSARAE BIHARSHARIF NALANDA

(Name & Address of the school) on 07/05/2025 (Date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal: Hareet Kaur Bachchu

Name : Hareet Kaur Bachchu

Designation : Assistant Engineer

Assistant Engineer of अवर प्रमण्डल पदाधिकारी
the Govt. Public Health सोसायटी (P.H. Sub. Division)
Authorised officer of the Local Body बिहार प्रमण्डल (नालन्दा)

Name & Address of the Office / Department :

To

DR. SWATI

PRINCIPAL

EDUEN WORLD SCHOOL SALEMPUR SOHSARAE BIHARSHARIF
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Government of Bihar
Public Health Engineering Department
Water Quality Report**

Format: I


District Name: Nalanda

Division Name: Public Health Engineering Division, Bihar Sharif & Hilsa

Sample Collected by :- DR SWATI

Date of Sampling :- 03.05.2025

Sl. No.	Block	Panchayat	Village	Location of Source	Test result														Source of Water
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	T.Coli	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	NAGAR NIGAM	SALEMPUR SOHSARAI	SALEMPUR SOHSARAI	EDUGEN WORLD SCHOOL	7.83	0.21	810	526	200	48	19.2	.40	210	0.1	0.156	10.8	0.864	NEGATIVE	Tube Well
2	NAGAR NIGAM	SALEMPUR SOHSARAI	SALEMPUR SOHSARAI	EDUGEN WORLD SCHOOL	7.1	0.12	445	290	150	40	12	20	160	0.08	0.089	10.1	0.356	NEGATIVE	RO
Desirable Limit*					6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-	-
Permissible Limit* in absence of alternate source					NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	**	-


 Chemist
 05/05/2025
 Public Health Division, Bihar Sharif
 (Nalanda)
 Chemist
 Public Health Division
 Bihar Sharif (Nalanda)